



**TOWN OF STRATFORD  
PURCHASING DEPARTMENT  
STRATFORD, CONNECTICUT**

**BID No. 2014-054**

**Issued : August 8, 2014**

**Subject : Connors Lane Fence Installation**

**ADDENDUM #2**

**Q: With regards to the above bid, will "SS40" pipe (ASTM 1043-IC) be allowed on the project, or will the successful bidder be required to use full weight Schedule 40 (ASTM-IA) pipe?? This product is accepted for use by State of Connecticut agencies, including DOT.**

**A: The Town will consider "SS40" pipe (ASTM 1043-IC) as a suitable alternative.**

**ADDENDUM #2:**

**Contractor Signature:\_\_\_\_\_**