

ADDENDUM 1



New Water Coolers at: **Bunnell High School**

1 Bulldog Blvd
Stratford, CT 06614

TOWN PROJECT NUMBER: 2016-042

ISSUED FOR BID: 9/8/2016

PROJECT TEAM

Architects

GEDDIS ARCHITECTS

71 Old Post Road-Suite 101

P.O. Box 1020

Southport, CT 06890

Phone: (203) 256-8700

Fax: (203) 255-0004

MEP Engineers

DIVERSIFIED TECHNOLOGY CONSULTANTS

2321 Whitney Avenue

Hamden, CT 06518

Phone: (203) 239-4200

Fax: (203) 234-7376

The work shall be carried out in accordance with the following supplemental instructions and in accordance with the Contract Documents.

MISCELLANEOUS CHANGES / CLARIFICATION

Requests for Information (RFI's)

- See attached RFI Log

END OF ADDENDUM NO. 1

RFI LOG					
New Water Coolers:					
Bunnell High School					
Date: 9/8/2016					
Geddis Architects /DTC Engineers					
	Question	Date Received	Directed To	Response	Response Date
1	Please clarify allowable work hours and days?	9/7/2016	Geddis	All work must be done outside of school hours. Work can be completed after school until 11:00, weekends, or school holidays.	9/8/2016
2	Please clarify model # for the EWC-HC water cooler. The listed model number is the same as the Oasis above it. Please advise.	9/8/2016	Geddis	Water cooler model number is noted correctly, but manufacturer is Oasis, and not Elkay. EWC and EWC-HC were originally indicated to differentiate between standard mounting height and accessible mounting height. All water coolers shall be mounted 35" from floor to spout outlet.	9/8/2016
3					